





Number	21-004738-PR33 (NW-K08-02040609-en-02)
Owner	Meeseburg Großhandel KG Westerallee 162 24941 Flensburg Germany
Product	One component canned foam (OCF)
Designation	blaugelb 1K Pistolenschaum Premium Allseason XXL Klasse E
Details	Material polyurethane foam Application foam gun Density approx. 18 kg/m ³ (manufacturer's information) Colour yellow Test state foamed with oversize, cut flush / cut to size after curing / conditioning

Results Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

	Characteristics	Result of the test
	Air permeability in new condition according to EN 12114	$a < 0.1 \text{ m}^3/[(\text{m h (daPa)}^{2/3})]$ Joint width $w = 20 \text{ mm}$, Joint depth $d = 70 \text{ mm}$
	Sound reduction of joints according to EN ISO 717-1 (and EN ISO 10140-1)	$[R_{s,w} (C; C_{tr}) \geq 63 \text{ (-2;-5) dB}]$ Joint width $w = 20 \text{ mm}$, Joint depth $d = 100 \text{ mm}$
	Thermal conductivity according to EN 17333-5	$\lambda_{10} = 0.039 \text{ W/(m K)}$ Insulation board 270 x 270 x 30 mm ³
	Water vapour resistance factor according to EN ISO 12572 – Climate set A	$\mu_{0/50} = 12$ Insulation cylinder $t = 94 \text{ mm}$, $d = 70 \text{ mm}$

ift Rosenheim
14.11.2023

Wolfgang Jehl, Dipl.-Ing. (FH)
Product Manager
Division Testing

Martin Heßler, Dipl.-Ing. (FH)
Project Engineer
Division Testing

Basis *)

EN 12114 : 2000
EN ISO 717-1 : 2020
EN ISO 10140-1 : 2021
EN 17333-5 : 2020
EN ISO 12572 : 2016

*) and the equivalent national versions (e.g. DIN EN)

ift Nachweis : 21-004738-PR21
(NW-K05-02040609-en-02)

replaces ift Nachweis :
21-004738-PR33
(NW-K05-02040609-en-01)

ift Product certification QM 360
contract no. 188 9026567 dated
02.09.2022

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies..

Identitäts-Check



www.ift-rosenheim.de/ift-geprueft
ID: 456-37CA5